

VOC Content Test Certificate

Friday October 26th, 2007

Supplier: Bio Products Australia Pty Ltd (25 Aldgate Terrace, Bridgewater South Australia 5155)

Sample Description: Bio Wall Paint

Date Tested: October 2007

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings.

Test Data:

Bio Wall Paint
<1 grams per Litre as VOC content of material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant